

CERTIFICATE OF TEST

CERTIFICATE No. 16251

This certificate is to certify that the areas listed below have been treated by The Staging Company Pty Ltd, an approved and accredited licensed applicator.

Biofax 2000 when applied to the guidelines set out in the application manual will convert a fabric or any porous material into a fire resistant product that performs to the guide-lines in the Australian Standards 1530 part 2 and part 3 C1.10 of the Australian Building Code.

Prior to application, the accredited applicator has performed appropriate tests to ensure that Biofax 2000 when applied to the areas treated will produce the minimum standards for retardants as set out in the Australian Building Code.

Biofax Australian Pty Ltd Guarantees that the product Biofax 2000 produces the following indices as tested by the C.S.I.R.O Test Report N92-0388 here stated

	Ignitability Index	Spread of Flame Index	Heat Evolved Index	Smoke Development Index
Part 2	0	0	0	0
Part 3	0	0	0	1

The licensed applicator in conjunction with Biofax Australia hereby guarantees;

a: that the accredited licensed applicator has applied the product Biofax 2000 to the areas as stated in the above noted service docket.

b: As a result of this application to the area Biofax Australia extend to you the customer a product performance guarantee.

c: That as a result of this application the areas treated have a reduction in natural fire risk of over 80%.

The performance of the product and in turn this guarantee can be made invalid resulting in the reduction in protection of your property of;

a: The carpet or areas treated are washed or stem cleaned. (Note: spot cleaning and or dry cleaning will not affect the performance of the retardant).

b: If the areas treated are not inspected and approved by a licensed applicator on or before the end of each yearly anniversary.

Certificate issued by; Biofax Australia Pty Ltd on the 1st January 1994
Licensed applicators name: The Staging Company Pty Ltd
The Staging Company License No. TT95303
Certification No. VM2777701